

General - Général

Language/Langue: English

KEY
User Inputs in blue
User inputs selected from drop-down menus in green
Outputs or imported data in yellow

	Province/Territory ▼	Location ▼	HDD
House Location	BRITISH COLUMBIA		
Weather Location	BRITISH COLUMBIA	SHERINGHAM POINT	2942

Greener Homes Initiative Questions	
At the time of the post-retrofit evaluation, is there at least one head per floor including basements with a ceiling height of 1.8 m or more or is there a central system distributing heat to the entire house?	Yes
Is a heat pump upgrade being recommended in the D file?	No changes to heat pumps

ccASHPs List - Liste TABT

Item	ccASHP 1		ccASHP 2		ccASHP 3		ccASHP 4		ccASHP 5		
AHRI Number	210725099										
Presence ▾	P, N and ES files		Please Select		Please Select		Please Select		Please Select		
Central Equipment Type ▾	Compact Ducted Mini- or Multi-split system		Please Select		Please Select		Please Select		Please Select		
Number of heads / supply outlets ▾	10 Heads		Please Select		Please Select		Please Select		Please Select		
Total number of systems that are identical to this one ▾	N/A (this system is unique)		N/A (this system is unique)		N/A (this system is unique)		N/A (this system is unique)		N/A (this system is unique)		
Eligible for the Canada Greener Homes Initiative	No		No		No		No		No		
NEEP database	Yes		No		No		No		No		
ENERGY STAR	No		No		No		No		No		
Manufacturer	DAIKIN										
Outdoor Unit Model Number	5MXS48WVJU9										
Indoor Unit Model Number	FDMQ24WVJU9, FDMQ24WVJU9										
ccASHP Fields											
Rated heating capacity	BTU/h	46500									
HSPF Region IV	BTU/h/W										
HSPF2 Region V	BTU/h/W	6.6									
SEER	BTU/h/W										
SEER2	BTU/h/W	14.5									
Capacity Maintenance	%	77									
COP at 5°F (-15°C)	kW/kW	1.88									
ccASHP Data											
	Temperature	Max. Capacity BTU/h	COP at Max. Cap. kW/kW	Max. Capacity BTU/h	COP at Max. Cap. kW/kW						
	95°F (35°C)	43000	2.4								
	47°F (8.3°C)	51800	2.76								
	17°F (-8.3°C)	34400	2.14								
	5°F (-15°C)	36260	1.88								
Notes											

ASHP List - Liste TA

Item	ASHP 1		ASHP 2		ASHP 3		ASHP 4		ASHP 5	
AHRI Number										
Eligible for the Canada Greener Homes Initiative	No									
Presence ▾	Please Select									
Central Equipment Type ▾	Please Select									
Number of heads / supply outlets ▾	Please Select									
ENERGY STAR ▾	Please Select									
Total number of systems that are identical to this one ▾	N/A (this system is unique)									
Values known ▾	Please Select									
Manufacturer										
Outdoor Unit Model Number										
Indoor Unit Model Number										
Values										
Heating Capacity (1.25 x cooling load if unknown)	BTU/h									
Heating Efficiency	HSPF Region V (5)									
Cooling Efficiency	SEER									
Cutoff Temp. (leave blank if unknown)	°C									
Notes										

D File (Upgr.)-Fichier D amél.

Main		Season		Fans / Pumps		Baseboards		Heat Pump - Air	
------	--	--------	--	--------------	--	------------	--	-----------------	--

Equipment Unit Function Heating/Cooling		Equipment Information Manufacturer	
Central Equipment Type		Model	
Number of heads		AHRI	
Specifications Output Capacity Capacity btu/hr Calculated 0.00		Crankcase Heater Sensible Heat Ratio 60 W 0.76	
Heating Efficiency <input checked="" type="radio"/> COP (@ Rating Temp) <input type="radio"/> HSPF (Region V) <input type="radio"/> HSPF2 (Region V)		Openable Window Area 0 %	
Cooling Efficiency <input checked="" type="radio"/> COP (@ 35°C) <input type="radio"/> SEER <input type="radio"/> SEER2		<input type="checkbox"/> Cold Climate Heat Pump	
Temp. Cutoff Type Cutoff Temp. °C			
Temp. Rating Type Rating Temp. °C 8.3 C (47 F) 8.3			

