

Client TEKloch Homes Date Apr 16/2026
 Development Rosefinch Pl Ph 0 Lot 10 File # 7948 N 81153
 Address 924 Rosefinch Pl WO # 1058
 City Langford Postal Code 0 Vol. 15984.3 Ft³
 Target Step 3 ACH = (CFM/Vol)*60

BLOWER DOOR TEST

By: SGK

Wind <u>Med</u>	Zone: Main - Volume = <u>13235.6</u> ft ³			Zone: Suite - Volume = <u>2748.8</u> ft ³		
	Zone 1 Pa	Zone 1 cfm	Zone 2 Pa	Zone 2 Pa	Zone 2 cfm	Zone 1 Pa
Ext. Temp <u>51.8</u>	<u>-50.3</u>	<u>556</u>	<u>-7.4</u>	<u>-49.9</u>	<u>185</u>	<u>-3.3</u>
	<u>-45.3</u>	<u>519</u>	<u>-7.2</u>	<u>-44.7</u>	<u>171</u>	<u>-3.2</u>
Int. Temp <u>68.0/66.2</u>	<u>-39.8</u>	<u>480</u>	<u>-6.9</u>	<u>-39.8</u>	<u>153</u>	<u>-3.0</u>
	<u>-35.3</u>	<u>439</u>	<u>-6.7</u>	<u>-34.9</u>	<u>140</u>	<u>-2.9</u>
Initial Pa. <u>-1.1/-1.4</u>	<u>-30.3</u>	<u>402</u>	<u>-6.5</u>	<u>-29.9</u>	<u>127</u>	<u>-3.0</u>
	<u>-25.6</u>	<u>354</u>	<u>-6.2</u>	<u>-24.5</u>	<u>113</u>	<u>-2.8</u>
Final Pa. <u>-1.5/-0.7</u>	<u>-20.8</u>	<u>320</u>	<u>-6.0</u>	<u>-20.0</u>	<u>101</u>	<u>-2.8</u>
	<u>-15.4</u>	<u>255</u>	<u>-5.6</u>	<u>-16.6</u>	<u>89</u>	<u>-2.7</u>
Ring Size <u>B, C, C</u>						
Backdraft						

WINDOWS

Label	Dir	#	Op	Width	Height	OH	Hdr Ht	v
W2.1-L-Living	Picture	2		24.00	24.00			
W2.2-B-Living	Patio Door	1		72.00	80.00			
W2.3-B-Living	Slider	1		48.00	48.00			
W2.4-R-Living	Picture	1		60.00	24.00			
W2.5-R-Kitchen	Slider	1		42.00	42.00			
W2.6-F-Pantry	Slider	1		24.00	48.00			
W2.7-F-Laundry	Slider	1		24.00	48.00			
W2.8-L-Powder	Slider	1		36.00	24.00			
W3.1-L-Stairs	Slider	1		24.00	36.00			
W3.2-B-Master	Slider	1		60.00	48.00			
W3.3-R-Ensuite	Slider	1		24.00	36.00			
W3.4-R-Bdrm	Slider	1		48.00	48.00			
W3.5-F-Bdrm	Slider	1		48.00	48.00			
W3.6-F-Bath	Slider	1		24.00	36.00			
Ws1.1-R-Kitchen	Slider	1		48.00	36.00			
Ws1.2-R-Bath	Slider	1		24.00	36.00			
Ws1.3-L-Bath	Slider	1		36.00	24.00			
Ws1.4-L-Bdrm	Slider	1		48.00	36.00			

DOORS & LITES

Label	Dir	#	Op	Width	Height	OH	Hdr Ht	v
D1.1-lite	Picture	1		21.00	16.00			
Ds1.1-lite	Picture	1		21.00	35.00			
D1.1-HouseEntry	Fibreglass ...			6.67	3.00			
D1.2-Garage	Fibreglass ...			6.67	2.67			
Ds1.1-SuiteEntry	Fibreglass ...			6.67	2.67			

SFH with secondary suite on main floor
3 levels on SOG (walkout)

Client TEKloch Homes
 Development Rosefinch Pl Ph 0 Lot 10
 Address 924 Rosefinch Pl
 City Langford Postal Code 0
 Target Step 3

Date Apr 16 / 2026
 File # 7948 N 81153
 WO # 1058
 Vol. 15984.3 Ft³
 ACH = (CFM/Vol)*60

BLOWER DOOR TEST

CHECKLIST

Data & Photo Documentation Checklist

<p>House: Front showing address <input checked="" type="checkbox"/></p> <p>All sides with all openings <input checked="" type="checkbox"/></p> <p>Crawl: Total height = <input checked="" type="checkbox"/></p> <p>Wall insulation: <input checked="" type="checkbox"/></p> <p>Floor (above) insulation: <input checked="" type="checkbox"/></p> <p>Heating.: ASHP outdoor unit <input checked="" type="checkbox"/></p> <p>+ label (Energy Star _____) <input checked="" type="checkbox"/></p> <p>ASHP indoor unit + label <input checked="" type="checkbox"/></p> <p>- type: <u>Mini split x 3</u></p> <p>- location: <u>Main Living, Master Suite</u></p> <p>EBB unit (each floor) <input checked="" type="checkbox"/></p> <p>+ label <input checked="" type="checkbox"/></p> <p>- location: <u>All floors</u></p> <p>Furnace / Boiler unit <input checked="" type="checkbox"/></p> <p>+ label (Energy Star _____) <input checked="" type="checkbox"/></p> <p>- type: _____</p> <p>- location: _____</p> <p>DHW: Main house unit + pipes <input checked="" type="checkbox"/></p> <p>+ label (Energy Star _____) <input checked="" type="checkbox"/></p> <p>- location: <u>Garage</u></p> <p>Suite unit + pipes <input checked="" type="checkbox"/></p> <p>+ label (Energy Star _____) <input checked="" type="checkbox"/></p> <p>- location: _____</p>	<p>Whole-house ventilation:</p> <p>HRV + ducts <input checked="" type="checkbox"/></p> <p>+ label (Energy Star _____) <input checked="" type="checkbox"/></p> <p>- HRV location: _____</p> <p>- ducts type: _____</p> <p>- ducts location: _____</p> <p>Supplemental ventilation:</p> <p>Bathroom exhaust fan 1 <input checked="" type="checkbox"/></p> <p>Bathroom exhaust fan 2 <input checked="" type="checkbox"/></p> <p>Supply fan: <input checked="" type="checkbox"/></p> <p>Utility fan: <input checked="" type="checkbox"/></p> <p>Range hood vented outdoors <input checked="" type="checkbox"/></p> <p>Dryer <input checked="" type="checkbox"/></p> <p>Attic: Space photos <input checked="" type="checkbox"/></p> <p>Insulation height = <input checked="" type="checkbox"/></p> <p>Basement Wall: Interior wide-angle <input checked="" type="checkbox"/></p> <p>Exposed Floor: Underside <input checked="" type="checkbox"/></p> <p>Fireplace: Unit - type + label <input checked="" type="checkbox"/></p> <p>Window / Door Label: <input checked="" type="checkbox"/></p> <p>Low-flush toilets: <u>4</u> <input checked="" type="checkbox"/></p> <p>Blower door installed: Main House <input checked="" type="checkbox"/></p> <p>Suite <input checked="" type="checkbox"/></p>
--	---