

Client TEKloch Homes
 Development Rosefinch Pl Ph 0 Lot 4
 Address 3485 Vision Way
 City Langford Postal Code 0
 Target Step 3

Date Jun 15/2026
 File # 7948 N 81592
 WO # 1058
 Vol. 15753.4 Ft³
 ACH = (CFM/Vol)*60

BLOWER DOOR TEST

By: SGW

Wind	Zone: Main - Volume = 13047.0 ft3			Zone: Suite - Volume = 2706.4 ft3		
	Zone 1 Pa	Zone 1 cfm	Zone 2 Pa	Zone 2 Pa	Zone 2 cfm	Zone 1 Pa
Ext. Temp <u>78.8</u>	<u>50.0</u>	<u>521</u>	<u>10.7</u>	<u>50.8</u>	<u>175</u>	<u>2.3</u>
	<u>44.5</u>	<u>486</u>	<u>10.1</u>	<u>45.4</u>	<u>162</u>	<u>2.1</u>
Int. Temp <u>76.6 68.0</u>	<u>40.4</u>	<u>443</u>	<u>9.5</u>	<u>40.0</u>	<u>149</u>	<u>1.9</u>
	<u>35.6</u>	<u>417</u>	<u>8.3</u>	<u>34.8</u>	<u>134</u>	<u>1.7</u>
Initial Pa. <u>0.5 0.0</u>	<u>29.8</u>	<u>365</u>	<u>7.1</u>	<u>30.5</u>	<u>126</u>	<u>1.6</u>
	<u>25.7</u>	<u>336</u>	<u>5.9</u>	<u>25.6</u>	<u>110</u>	<u>1.4</u>
Final Pa. <u>0.2 0.3</u>	<u>19.8</u>	<u>296</u>	<u>4.3</u>	<u>19.6</u>	<u>93</u>	<u>1.2</u>
	<u>15.2</u>	<u>242</u>	<u>3.1</u>	<u>14.7</u>	<u>77</u>	<u>1.0</u>
Ring Size <u>B, C C</u>						
Backdraft						

WINDOWS

Label	Dir	#	Op	Width	Height	OH	Hdr Ht	v
W1.1-F-Foyer			Picture			1	24.00	36.00
W2.1-F-Stairs			Picture			1	36.00	30.00
W2.2-F-Dining			Slider			1	60.00	48.00
W2.3-L-Living			Picture			2	24.00	24.00
W2.4-B-Living			Patio Door			1	72.00	80.00
W2.5-B-Living			Slider			1	60.00	48.00
W3.1-F-Staris			Picture			1	30.00	30.00
W3.2-F-Bdrm			Slider			1	60.00	48.00
W3.3-L-Bdrm			Slider			1	48.00	36.00
W3.4-B-Master			Slider			1	60.00	48.00
Ws1.1-L-Kitchen			Slider			1	48.00	36.00
Ws1.2-R-Bath			Slider			1	36.00	24.00
Ws1.3-R-Bdrm			Slider			1	48.00	36.00

DOORS & LITES

Label	Dir	#	Op	Width	Height	OH	Hdr Ht	v
D1.1-lite			Picture			1	21.00	16.00
Ds1.1-lite			Picture			1	21.00	35.00
D1.1-HouseEntry			Fibreglass ...				6.67	3.00
D1.2-Garage			Fibreglass ...				6.67	2.67
Ds1.1-SuiteEntry			Fibreglass ...				6.67	3.00

SFH with secondary suite on main floor
 3 levels on SOG (walkout)

Client TEKloch Homes
 Development Rosefinch Pl Ph 0 Lot 4
 Address 3485 Vision Way
 City Langford Postal Code 0
 Target Step 3

Date Jun 15/2026
 File # 7948 N 81592
 WO # 1058
 Vol. 15753.4 Ft³
 ACH = (CFM/Vol)*60

BLOWER DOOR TEST

CHECKLIST

Data & Photo Documentation Checklist

<p>House: Front showing address <input checked="" type="checkbox"/> All sides with all openings <input checked="" type="checkbox"/></p> <p>Crawl: Total height = <input checked="" type="checkbox"/> Wall insulation: <input checked="" type="checkbox"/> Floor (above) insulation: <input checked="" type="checkbox"/></p> <p>Heating.: ASHP outdoor unit <input checked="" type="checkbox"/> + label (Energy Star _____) <input checked="" type="checkbox"/> ASHP indoor unit + label <input checked="" type="checkbox"/> - type: <u>Mini Split x 3</u> - location: <u>Main Living, Master Suite</u> EBB unit (each floor) <input checked="" type="checkbox"/> + label <input checked="" type="checkbox"/> - location: <u>All Floors</u> Furnace / Boiler unit <input checked="" type="checkbox"/> + label (Energy Star _____) <input checked="" type="checkbox"/> - type: _____ - location: _____</p> <p>DHW: Main house unit + pipes <input checked="" type="checkbox"/> + label (Energy Star _____) <input checked="" type="checkbox"/> - location: <u>Garage</u> Suite unit + pipes <input checked="" type="checkbox"/> + label (Energy Star _____) <input checked="" type="checkbox"/> - location: _____</p>	<p>Whole-house ventilation: HRV + ducts <input checked="" type="checkbox"/> + label (Energy Star _____) <input checked="" type="checkbox"/> - HRV location: _____ - ducts type: _____ - ducts location: _____</p> <p>Supplemental ventilation: Bathroom exhaust fan 1 <input checked="" type="checkbox"/> Bathroom exhaust fan 2 <input checked="" type="checkbox"/> Supply fan: <input checked="" type="checkbox"/> Utility fan: <input checked="" type="checkbox"/> Range hood vented outdoors <input checked="" type="checkbox"/> Dryer <input checked="" type="checkbox"/></p> <p>Attic: Space photos <input checked="" type="checkbox"/> Insulation height = <input checked="" type="checkbox"/></p> <p>Basement Wall: Interior wide-angle <input checked="" type="checkbox"/></p> <p>Exposed Floor: Underside <input checked="" type="checkbox"/></p> <p>Fireplace: Unit - type + label <input checked="" type="checkbox"/></p> <p>Window / Door Label: <input checked="" type="checkbox"/></p> <p>Low-flush toilets: <u>4</u> <input checked="" type="checkbox"/></p> <p>Blower door installed: Main House <input checked="" type="checkbox"/> Suite <input checked="" type="checkbox"/></p>
--	---