


3572 Paperbark Cres,
Victoria, BRITISH COLUMBIA, V9C 3A6

ENERGUIDE

Data collected: July 12, 2018
File number: **7926N00341**
Evaluated by: Brooke Gallupe

59 This House
GJ/year



▲ 0 GJ/year
Best energy performance

▲ 81 GJ/year
A typical new house

Uses most energy

One gigajoule (GJ) equals the energy from two BBQ propane tanks

Rated Annual Energy Consumption	59 GJ
• Electricity	49
• Natural gas	10
On-site renewable energy contributions	- 0 GJ
• Electricity	0
• Solar water heating	0
EnerGuide Rating:	= 59 GJ

Breakdown of Rated Annual Energy Consumption:

A	Space heating	23%
B	Space cooling	5%
C	Water heating	27%
D	Ventilation	1%
E	Lights & appliances	20%
F	Other electrical	24%

Rated Energy Intensity: **0.20 GJ/m²/year**
Rated Greenhouse Gas Emissions: **0.7 tonnes/year**

Figures may not add up due to rounding.

The energy consumption indicated on your utility bills may be higher or lower than your EnerGuide rating. This is because standard assumptions have been made regarding how many people live in your house and how the home is operated. Your rating is based on the condition of your house on the day it was evaluated.

Quality assured by: City Green Solutions

Builder: Langdon Weir Construction

Visit NRCan.gc.ca/myenergguide



Natural Resources
Canada

Ressources naturelles
Canada

Canada